

## WATER SERVICE PIPE SIZING

## **PART 9 – RESIDENTIAL**

Water service pipe sizes for residential buildings containing one or more dwelling units may be sized using this form. Refer to the Ontario Building Code for additional information.

## Part 1 - Hydraulic Load (Fixture Unit) Calculation

Fixture or Device	Minimum Size of Supply Pipe	Hydraulic Load (Fixture Units)	Quantity	Total Hydraulic Load (Fixture Units)
Bathroom Group <sup>(a)</sup>	Зирріу Ріре	(i ixeare offics)		Load (Fixture Offics)
Bathroom group <sup>(a)</sup> with 6 LPF flush tank	I .	3.6		
Bathroom group <sup>(a)</sup> with greater than 6 LPF flush tank	-	6.0		
(a) Bathroom group means a group of plumbing	fixtures installed in the same	e room, consisting of one lav	atory, one water close	t and either one
bathtub, with or without a shower, or one o	ne-handed shower.			
Other than a Bathroom Group:				
Bathtub with or without shower head	1/2"	1.4		
Bathtub with ¾ in. spout,	3/4''	10		
Shower head, 9.5 L/min or less	1/2"	1.4		
Shower head, more than 9.5 L/min	1/2"	2.0		
Bidet	3/8"	2.0		
Clothes washer	1/2"	1.4		
Dishwasher	3/8"	1.4		
Water closet, 6 LPF or less with flush	3/8"	2.2		
Hose bibb ½" supply	1/2"	2.5		
Hose bibb ¾" supply	3/4"	3.0		
Bathroom sink (lavatory)	3/8"	0.7		
Bar sink	3/8"	1		
Kitchen sink, 8.3 L/min or less	3/8"	1.4		
Laundry sink	3/8"	1.4		
Other:	·			
	1		Total:	

## Part 2 – Sizing of the Water Service

Maximum Hydraulic Load (fixture units)	Maximum Allowable Length (m)	Water Service Pipe (in)
26 <sup>(b)</sup>	-	3/4
17	30	
19	24	3/4
21	18	
36	30	
41	24	1
42	18	
83	30	1-1/2

(b)	Only	applies to	a single	dwelling	unit house.
-----	------	------------	----------	----------	-------------

Existing water pipe size: in	New water pipe size*: in.	Water service length: m

https://www.peelregion.ca/services/water/sewer-connection/

Municipal Address:	Name:	BCIN, if applicable:	Date:

<sup>\*</sup>New water service connections or upgrades require Peel Region approval. For more information please visit: