



1. MEASUREMENTS IN METRES AND/OR MILLIMETRES UNLESS OTHERWISE SHOWN.
2. CONTRACTOR TO BE RESPONSIBLE FOR LOCATION OF ALL EXISTING UNDERGROUND & OVERHEAD UTILITIES. VARIOUS UTILITIES CONCERNED TO BE GIVEN REQUIRED ADVANCE NOTICE PRIOR TO ANY DIGGING, FOR STAKE OUT. THE CONSULTANT ASSUMES NO RESPONSIBILITY FOR THE ACCURACY OF THE LOCATION OF EXISTING UTILITIES AS INDICATED ON THIS DRAWING.
3. THE INFORMATION CONTAINED ON THIS PLAN PERTAINS TO THE INSTALLATION OF NEW MUNICIPAL SERVICING ONLY AND SHALL NOT BE RELIED UPON BY A THIRD PARTY FOR ANY OTHER DESIGN AND/OR CONSTRUCTION RELATED PURPOSES (INCLUDING PUBLIC & PRIVATE SERVICING/UTILITY LOCATES, SHORING DESIGN AND FIELD LAYOUT, UTILITY DESIGN AND CONSTRUCTION, AND ALL OTHER DESIGN AND CONSTRUCTION RELATED ACTIVITIES). ALL THIRD PARTIES ARE RESPONSIBLE FOR OBTAINING THEIR OWN LOCATES FOR ANY PUBLICLY OR PRIVATELY HELD INFRASTRUCTURE WITHIN OR ADJACENT TO THE SUBJECT DEVELOPMENT.

2.	ISSUED FOR OPA/DPOS #2	10/25/2023	K.L.
1.	ISSUED FOR OPA/ZBA #1	07/29/2022	K.L.
No.	REVISIONS/ISSUED	DATE	BY CITY

counterpoint ENGINEERING
 COUNTERPOINT ENGINEERING INC.
 8395 Jane St., Suite 100, Vaughan, ON L4K 5Y2 Phone 905.326.1404 Fax 905.326.1405

LICENSED PROFESSIONAL ENGINEER
 K.Ly
 100190179
 OCT 25, 2023
 PROVINCE OF ONTARIO

APPLICANT:
HAZELVIEW INVESTMENTS
 1133 YONGE STREET, 4TH FLOOR
 TORONTO, ON M4T 1W1
 PHONE: 1-888-949-8439

CONTACT: DEREK WEI - dwei@hazelview.com

SITE LOCATION:
RESIDENTIAL/COMMERCIAL DEVELOPMENT
 DUNDAS & MATTAWA
 1580-1590 & 1650 DUNDAS STREET EAST
 MISSISSAUGA, ON
 SITE PLAN FILE No.:

SITE SERVICING PLAN

DESIGNED BY:	K.L.	CHECKED BY:	D.L.	DATE:	OCTOBER 2023
DRAWING BY:	K.L.	CHECKED BY:	D.L.	PROJECT NO.:	20129
SWM BY:	K.L.	CHECKED BY:	D.L.	DRAWING NO.:	SP-1

SCALE: 1:500m
 0m 5m 10m 20m 30m

BLDG	SAN Connection	STM Connection
BLDG A	CTRL MH3A	CTRL MH1
BLOCK B	None	CTRL MH7
BLDG C	CTRL MH3A	CTRL MH3
BLDG E	CTRL MH3A	CTRL MH2
BLDG F	CTRL MH4A	CTRL MH4
BLDG G	CTRL MH6A	CTRL MH8
Blundell Rd	None	CTRL MH5
Adjacent Property	Ex. MH9	None

- NOTES:**
1. ALL PROPOSED FIRE AND DOMESTIC WATERMAIN CONNECTIONS TO BE MADE WITH TAPPING SLEEVE WITH VALVE BOX AS PER REGION OF PEEL STANDARD 1-8-4.
 2. ALL PROPOSED WATERMAIN CONNECTIONS TO BE MADE AS PER REGION OF PEEL STANDARD 1-8-3.
 3. ALL DETECTOR CHECK VALVES TO BE INSTALLED IN CHAMBER AS PER REGION OF PEEL STANDARD 1-3-1.